

PHONE: 724-226-2500  
FAX: 724-226-3683  
TDD: 724-226-2500

# HARRISON TOWNSHIP

## WATER AUTHORITY

1705 REAR FREEPORT ROAD  
NATRONA HEIGHTS, PA 15065

MARK KRUMENACKER  
Chairman

ARTHUR BARKER  
First Vice Chairman

WILLIAM R. POSTON  
Second Vice Chairman

GARY MEANOR  
Secretary

GEORGE E. CONROY  
Treasurer

CHARLES V. CRAIG  
General Manager

### ANNUAL DRINKING WATER QUALITY REPORT

**PWSID#: 5020108**  
**REPORT YEAR 2020**

*Este informe contiene informacion importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.* (This report contains important information about your drinking water. Have someone translate it for you or speak with someone who understands it.)

#### **WATER SYSTEM INFORMATION:**

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact our office at (724) 226-2500 and speak to the General Manager Charles Craig. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings held on the third Monday of each month at the Authority Office located at 1705 Rear Freeport Road. Our constant goal is to provide you with a dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our resources. We are committed to ensuring the quality of your water.

#### **SOURCE(S) OF WATER:**

Our water source is the Allegheny River, and our raw water intake is located at mile point 24 just above Lock No. 4. A Source Water Assessment of our Allegheny River Intake was completed by the PA Department of Environmental Protection (PA DEP) in 2014 in cooperation with 4 other community water systems and the Allegheny County Health Department in order to develop a regional plan for those water suppliers with surface water intakes on the lower portion of the Allegheny River. The Assessment has found that our source is potentially most susceptible to accidental spills from businesses and transportation and runoff from non-point sources. Overall, our source has a moderate risk of significant contamination. A summary report of the Assessment is available on the Source Water Assessment eLibrary page at the following address:

[www.depgreenport.state.pa.us/elibrary/GetDocument?docId=3205&DocName=HARRISONTOWNSHIPWATERAUTHORITY.PDF](http://www.depgreenport.state.pa.us/elibrary/GetDocument?docId=3205&DocName=HARRISONTOWNSHIPWATERAUTHORITY.PDF)

Complete reports were distributed to municipalities, water suppliers, local planning agencies, and PA DEP offices. Copies of the complete report are available for review at the Records Management Unit of the PA DEP Southwest Regional Office, at (412) 442-4200.

Some People may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *CRYPTOSPORIDIUM* and other microbial contaminants are available from the *SAFE DRINKING WATER HOTLINE* (800-426-4791)

## **MONITORING YOUR WATER:**

The Harrison Township Water Authority routinely monitors for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2020. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The data has been noted on the sampling results table included on the following pages.

## **DEFINITIONS:**

**Action Level (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Level 1 Assessment** – A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment** – A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. Coli* MCL has occurred and/or why total coliform bacteria have been found in a water system on multiple occasions.

**Treatment Technique (TT)** – A required process intended to reduce the level of a contaminant in drinking water.

**pCi/L** = picocuries per liter (a measure of radioactivity)

**ppb** = parts per billion, or micrograms per liter ( $\mu\text{g/L}$ )

**ppm** = parts per million, or milligrams per liter ( $\text{mg/L}$ )

**ppq** = parts per quadrillion, or picograms per liter

**ppt** = parts per trillion, or nanograms per liter

**DETECTED SAMPLE RESULTS:**

<b>Chemical Contaminants:</b>								
<b>Contaminant</b>	<b>MCL in CCR Units</b>	<b>MCLG</b>	<b>Level Detected</b>	<b>Range of Detections</b>	<b>Units</b>	<b>Sample Date</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
Chlorine	MRDL = 4	MRDLG = 4	0.92	0.53-0.92	ppm	3/2020	N	Water additive used to control microbes
Barium	2	2	0.033		ppm	3/4/2020	N	Discharge of drilling wastes, Discharge from metal refineries, Erosion of Natural deposits
Fluoride	2	2	0.88		ppm	3/4/2020	N	Erosion of natural deposits, Water additive which promotes strong teeth, Discharge from fertilizer and aluminum factories
HAA5s	60	N/A	27.8	12.3-37.9	ppb	2020	N	By-product of drinking water disinfection
TTHMs	80	N/A	60.0	16.7-102	ppb	2020	N	By-product of drinking water disinfection
Pentachlorophenol	0.1	0	0.016		ppb	10/7/2020	N	Discharge from wood preserving factories

\*EPA's MCL for fluoride is 4 ppm. However, Pennsylvania has set a lower MCL to better protect human health

<b>Entry Point Disinfectant Residual</b>							
<b>Contaminant</b>	<b>Maximum Disinfectant Residual</b>	<b>Lowest Level Detected</b>	<b>Range of Detections</b>	<b>Units</b>	<b>Sample Date</b>	<b>Violation Y/N</b>	<b>Source of Contamination</b>
Chlorine	4.0	0.88	0.88-1.48	ppm	11/2/2020	N	Water additive used to control microbes

<b>Lead and Copper</b>							
<b>Contaminant</b>	<b>Action Level (AL)</b>	<b>MCLG</b>	<b>90<sup>th</sup> Percentile Value</b>	<b>Units</b>	<b># of sites above AL of total Sites</b>	<b>Violation Y/N</b>	<b>Sources of contamination</b>
Lead	15	0	0	ppb	0	N	Corrosion of household plumbing
Copper	1.3	1.3	0.03	ppm	0	N	Corrosion of household plumbing

<b>Turbidity</b>						
<b>Contaminant</b>	<b>MCL</b>	<b>MCL G</b>	<b>Level Detected</b>	<b>Sample Date</b>	<b>Violation Y/N</b>	<b>Source of contamination</b>
Turbidity	TT=1 NTU for a single measurement	0	0.03	Multiple Dates in 2020	N	Soil Runoff
	TT=at least 95% of monthly samples ≤0.3 NTU		100%	All samples in compliance	N	

<b>Total Organic Carbon (TOC)</b>					
<b>Contaminant</b>	<b>Range of % Removal required</b>	<b>Range of % Removal Achieved</b>	<b>Number of Quarters Out of Compliance</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
TOC	0-35%	43.3%-54.1%	0	N	Naturally present in the environment

**EDUCATIONAL INFORMATION:**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

**Information about Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Harrison Township Water Authority is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the *Safe Drinking Water Hotline* or at <http://www.epa.gov/safewater/lead>.

**HARRISON TOWNSHIP WATER AUTHORITY**